

## RESPONSE TO COMMENTS RECEIVED

\*\*\*\*\*

### Jody Wall

I like the inclusion of the AASHTO M-195 specification but it should not be limited to the 3/4 inch (19 mm) gradation. Depending on the area of the state and the concrete producer the gradation might be any of the 3 specified gradations of M-195. They are 3/4", 1/2" and 3/8".

Thanks Jody

Jody R.Wall, P.E.  
jwall@stalite.com  
Director of Research and Development  
Quality Control Manager  
Carolina Stalite Company

### RESPONSE

I have accepted the comment on Section 901 from Jody Wall and would like the verbiage of the last sentence of 901-4.2 to read: "Gradation shall meet the requirements of AASHTO M 195 for 3/4 in. (19 mm), 1/2 in. (12.5 mm) and 3/8 in. (9.5 mm)."