

## ORIGINATION FORM

### Proposed Revisions to the Specifications

(Please provide all information - incomplete forms will be returned)

Date:

Specification Section:

Originator:

Articles/Subarticles:

Telephone:

email:

Will the proposed revision involve Design Standard Index changes?      Yes      No

Roadway Design staff contacted (name):

Will the proposed revision involve PPM changes?      Yes      No

Roadway Design staff contacted (name):

Will the proposed revision involve CPAM changes?      Yes      No

Construction staff contacted (name):

Will the proposed revision involve Pay Item changes?      Yes      No

Estimates staff contacted (name):

Will the proposed revision involve SDG changes?      Yes      No

Structures staff contacted (name):

Will the proposed revision involve APL changes?      Yes      No

Product Evaluation staff contacted (name):

Will this revision necessitate any of the following:

Design Bulletin

Construction Bulletin

Estimates Bulletin

Are all references to external publications current?      Yes      No

If not, what references need to be updated (please include changes in the redline)?

Why does the existing language need to be changed?

Summary of the changes:

Are these changes applicable to all Department jobs?      Yes      No

If not, what are the restrictions?

Contact the State Specifications Office for assistance in completing this form.

Daniel Scheer 850-414-4130 [daniel.scheer@dot.state.fl.us](mailto:daniel.scheer@dot.state.fl.us)

Debbie Toole 850-414-4114 [deborah.toole@dot.state.fl.us](mailto:deborah.toole@dot.state.fl.us)

Frances Thomas 850-414-4101 [frances.thomas@dot.state.fl.us](mailto:frances.thomas@dot.state.fl.us)

Ray Haverty 850-414-4129 [ray.haverty@dot.state.fl.us](mailto:ray.haverty@dot.state.fl.us)



## *Florida Department of Transportation*

**RICK SCOTT**  
GOVERNOR

605 Suwannee Street  
Tallahassee, FL 32399-0450

**JIM BOXOLD**  
SECRETARY

### **MEMORANDUM**

**DATE:** May 27, 2015

**TO:** Specification Review Distribution List

**FROM:** Daniel Scheer, P.E., State Specifications Engineer

**SUBJECT:** Proposed Specification: **6300301 Conduit.**

In accordance with Specification Development Procedures, we are sending you a copy of a proposed specification change.

The changes are proposed by Chester Henson of the State Roadway Design Office to address ITS fiber optic cable that used the blown fiber method of installation. The current wording for conduit sealants did not require that it be a moisture resistant sealant.

Please share this proposal with others within your responsibility. Review comments are due within four weeks and should be sent to Mail Station 75 or online at <http://www2.dot.state.fl.us/ProgramManagement/Development/IndustryReview.aspx> . Comments received after **June 24, 2015**, may not be considered. Your input is encouraged.

DS/ot  
Attachment

## CONDUIT.

(REV 5-~~1227~~-15)

SUBARTICLE 630-3.1 is deleted and the following substituted:

**630-3.1 General:** Install the conduit in accordance with NEC or National Electrical Safety Code (NESC) requirements and the Design Standards. Consider the locations of conduit as shown in the Plans as approximate. Construct conduit runs as straight as possible, and obtain the Engineer's approval for all major deviations in conduit locations from those shown in the Plans. Include buried cable warning tape with all trenched conduit. Mark the location of the conduit system with route markers as shown in the Plans and approved by the Engineer. Ensure that all route markers used are new and consistent in appearance.

For conduit installed by directional bore, install in accordance with Section 555. For conduit installed by jack and bore, install in accordance with Section 556.

Use only intermediate metal conduit, rigid galvanized metal conduit, rigid aluminum conduit or PVC coated intermediate metal conduit for above-ground electrical power service installations and rigid galvanized metal conduit or rigid aluminum conduit for underground electrical power service installations. Meet the requirements of Section 562 for coating all field cut and threaded galvanized pipe.

Use Schedule 80 PVC or fiberglass reinforced epoxy conduit in structural elements in or on bridge decks.

Use HDPE with an SDR number less than or equal to 11, Schedule 80 PVC or Schedule 40 PVC for underground installations in earth or concrete for *ITS and* traffic control signal ~~and device~~ applications, *except, use only -*

~~Use HDPE with an SDR number less than or equal to 11 or Schedule 40 PVC for blown blown fiber optic cable installations on limited access facilities facilities ITS applications.~~

Use HDPE with an SDR number less than or equal to 13.5, Schedule 80 PVC, or Schedule 40 PVC for underground installations of electrical conduit in earth for lighting applications and landscape irrigation applications.

Use HDPE with an SDR number less than or equal to 13.5, Schedule 80 PVC, Schedule 40 PVC, or rigid galvanized metal for underground installations of electrical conduit in concrete for lighting applications.

Do not place more than the equivalent of three quarter bends or 270 degrees of bends, including the termination bends, between the two points of termination in the conduit, without a pull box. Obtain the Engineer's approval to use corrugated flexible conduits for short runs of 6 feet or less.

When a conduit installation changes from underground to above-ground, make the change a minimum of 6 inches below finished grade.

Install a No. 12 AWG pull wire or polypropylene cord inside the full length of all conduits. Ensure that a minimum of 24 inches of pull wire/cord is accessible at each conduit termination.

Ensure the conduit includes all required fittings and incidentals necessary to construct a complete installation.

When earth backfill and tamping is required, place backfill material as per Section 120 in layers approximately 12 inches thick, and tamp each layer to a density equal to or greater than the adjacent soil.

When backfilling trenches in existing pavement, use a flowable fill meeting the requirements of Section 121.

Provide a standard clearance between underground control cable and electrical service cable or another parallel underground electrical service cable that meets NESC requirements.

Prevent the ingress of water, dirt, sand, and other foreign materials into the conduit prior to, during, and after construction. ~~Exclude water and debris from buried conduit and from the top riser assembly of above-ground conduit using a foam sealing material, rubber plug, or other device designed for this application and approved by the Engineer.~~ *Seal the ends of conduit after wiring is complete with a moisture resistant sealant that is designed for this specific application.*

**630-3.1.1 Fiber Optic Cable Conduit:** Install the conduit system so the fiber optic cable maintains a minimum bend radius of 20 times the cable diameter. Use approved methods for connecting inner duct or conduit within or between plowed portions, trenched portions, and bored portions. Submit the conduit manufacturer's coupling method and material to the Engineer for approval.

SUBARTICLE 630-3.2 is deleted and the following substituted:

**630-3.2 Conduit Sizes:** Size the conduit to be used on all installations, unless otherwise shown in the Contract Documents. Use conduit of sufficient size to allow the conductor to be installed without any damage and meeting NEC requirements. Use conduit that is at least 2 inches in diameter, with the following exceptions:

For conduit protecting the ground wire on the side of a pole, use conduit that is at least 1/2 inch in diameter.

*For ITS applications where Contractor chooses to install fiber optic cable by blowing, use conduit that is at least 1-~~1/4~~1/4- inch in diameter.*

For traffic control signal and device electrical service conduit, use the minimum conduit size required by the local maintaining agency and the electrical service provider.