

3460302 PORTLAND CEMENT CONCRETE
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Katie Bettman
904-360-5391
katie.bettman@dot.state.fl.us

Comments: (11-25-15)

I'm not sure how it would work to require concrete delivery tickets to be submitted electronically, but 346-6.3 was not changed to be consistent with all other changes. The concrete for flowable fill in Section 121 was changed from furnish to submit.

346-6.3 Delivery Certification was not changed and states, "Ensure that an electronic delivery ticket is furnished with each batch of concrete before unloading at the placement site. The delivery ticket may be proprietary software or in the form of an electronic spreadsheet, but shall be printed."

Response:
