

4551505 STRUCTURES FOUNDATIONS
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Brian Hermany
561-370-1140

Comments: (12-23-15)

"In some cases the Engineer may require the Contractor to overream the outside diameter of the casing before placing the casing." Statement does not make sense to me. The casing is not being over reamed the excavation is.

Response:
