

4620100 POST TENSIONING  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

---

Karen Byram  
414-4353  
[karen.byram@dot.state.fl.us](mailto:karen.byram@dot.state.fl.us)

Comments: (12-1-15)

: In Section 462-5, the requirement to identify the APL number of the PTS needs to be added to the shop drawings. There is no way to identify the APL system used without that information.

Response:

\*\*\*\*\*