

4620100 POST TENSIONING
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Karen Byram
414-4353
karen.byram@dot.state.fl.us

Comments: (12-1-15)

: In Section 462-5, the requirement to identify the APL number of the PTS needs to be added to the shop drawings. There is no way to identify the APL system used without that information.

Response: Pre-approved PT systems are not tracked via the APL, they are handled by the Structures Design office. There is no APL number.
No change required.
