

Questions and Answers

1. Currently the plan calls to place 1 ½ type SP 9.5 with PG 76-22. It is typical for PG 67-22 for a parking lot with the amount of hand work that was required. Which is preferred?

The contractor has the option to use either PG 76-22 or PG 67-22.