

contact us | what's new | FAQ's | links

District One Construction

Proposal Number: T1441
Financial Project Number: 423276-1-52-01

Question	Response
On this project it doesnot show any concrete for sidewalks or curbs. Does this project get any type of road work or are the lights just going to be out in the grassy areas and later on a different project, Will another project be widening the road and installing Curbs / sidewalks on it?? Thanks	Answer Posted on 4/14/2011 @ 2:59PM:This lighting-only project will construct lighting in the grassed areas. No roadwork (roadway widening or curb construction) is included in this project.
As per the plans they are not showing any type of Concrete pads for the Light Poles or Junction boxes. are we to assume that the light pole and junction boxes do not get any type of Maintainance pads around the light pole or any Junction boxes???	Answer Posted on 4/22/2011 @ 8:50AM: The concrete pads shall be provided per FDOT Standard Index 17500.

Return to Bid Questions

Print Page

This site is maintained and published by the Florida Department of Transportation's District One Construction Office, located at 801 N Broadway, Bartow, FL 33830. (863) 519-2550

Site Contact Information

Back to the State Construction Office