



District Two Office

1109 South Marion Avenue
Lake City, FL 32025-5874
Phone Number: 386/961-7416
Fax: 386/961-7849

Proposal Number: T2397 21324365201

Question	Response
The HP Tape manufacturer recommends that the existing painted markings be removed by grinding method, is that going to be an acceptable method of removal or will the department require the removal be done by water blasting method.	6/17/11 1:48 PM - FDOT Specifications do not indicate a required method of removal. The Department will not direct methods. Removal methods are to be evaluated in accordance with FDOT Specifications, Section 713-4.
06/15/2011 05:04 PM The Question Period has closed.	06/15/2011 05:04 PM The Question Period has closed.

[Return to Bid Questions](#)

[Print Page](#)

This site is maintained and published by the Florida Department of Transportation's District Two Construction Office, located at 1109 South Marion Avenue, Lake City, FL 32025. 386/961-7416

[Site Contact Information](#)

[Back to the State Construction Office](#)