




[contact us](#) | [what's new](#) | [FAQ's](#) | [links](#)



Proposal Number: T1439
Financial Project Number: 427409-1-52-01

Question	Response
Are concrete mow pads required for pull boxes on Financial Project #427410-1-52-01 per Collier County's specifications?	Answer Posted on 3/23/2011 @ 2:08PM: No. Concrete mow pads shall not be required for pull boxes on Financial Project #427410-1-52-01.

[Return to Bid Questions](#)

[Print Page](#)

This site is maintained and published by the Florida Department of Transportation's District One Construction Office, located at 801 N Broadway, Bartow, FL 33830. (863) 519-2550

[Site Contact Information](#)

[Back to the State Construction Office](#)