




[contact us](#) | [what's new](#) | [FAQ's](#) | [links](#)



**District One Construction**

**Proposal Number: T1448**  
**Financial Project Number: 425215-1-52-01**

Question	Response
The striping plans indicate pavement markings to be "TMM" (Traffic Marking Material). What type of material is required for striping indicated as Traffic Marking Material?	Answer Posted on 5/19/2011 @ 11:11AM: Final Surface pavement markings shall be thermoplastic markings.

[Return to Bid Questions](#)

[Print Page](#)

This site is maintained and published by the Florida Department of Transportation's District One Construction Office, located at 801 N Broadway, Bartow, FL 33830. (863) 519-2550

[Site Contact Information](#)

[Back to the State Construction Office](#)