

Jan 25, 12

Responses to Contractors' Questions

District: 6

Contract: T6242

Letting Date: Jan 25, 12

Letting Location: State

422723-1-52-01: SR 959/SW 57 AVENUE RESURFACING

Question # 1

Q: Will the concrete crosswalk (Pay Item 350-2-10) require stamped concrete to be done? If so please specify what pattern and under what pay item this will be paid.

A: The concrete crossing will not require stamped concrete, but it will require color to match the other crossings as defined by the detail on Sheet 38.

Question # 2

Q: Will any of the concrete on the Coral Gables side of the road be "Coral Gables Beige"?

A: See General Note 21 on Sheet 27 for the sidewalk color as defined by the City of Coral Gables.

Question # 3

Q: On the Storm Pollution Prevention Plan we are required to install Rock Bags and Synthetic Bales, there is no pay item for this work. Under what pay item are we to include this cost?

A: Pay item 104-18 (Inlet Protection System) includes cost of rock bags and synthetic bales.

Question # 4

Q: DCE Memorandum 18-09, indicates we can use Class II HDPE pipe. Can HDPE pipe and fittings be used as an alternate on this project? Including yard drains?

A: HDPE pipe can be used as an optional pipe on this project.