



Bid Questions and Answers Report

Date & Time:

6/6/2012 1:51:15 PM

District Address: District 2 Construction Office, located at 1109 South Marion Avenue, Lake City, FL 32025

District Phone: (386) 961-7532

Proposal: T2416

Project: 426967-1-52-01

Letting Date: 6/6/2012

Location: CENTRAL OFFICE

Description: SR 100 (US 129)

---

Question: 761: Does the entire project need to be cleared R/W to R/W or only where required for construction? Posted: 5/29/2012 4:21:39 PM

---

Answer: Clear and grub only where required for construction. Status: ANSWER PUBLISHED

Posted: 5/29/2012 4:49:45 PM