



Bid Questions and Answers Report

Date & Time:

6/21/2012 1:45:43 PM

District Address: District 2 Construction Office, located at 1109 South Marion Avenue, Lake City, FL 32025

District Phone: (386) 961-7532

Proposal: T2426

Project: 208373-2-52-01

Letting Date: 6/20/2012

Localtion: CENTRAL OFFICE

Description: SR 10 (US 90)

---

Question: 890: Can Limerock Base be considered as an option to the Asphalt Base Only option listed for all the Optional Base Groups? Furthermore, per the Design Standards, Optional Base Group 13 is to be used in areas of widening 3FT or less in width. This project has new construction and widening of well over 3FT in width. Can a different Optional Base Group be used instead of OBG 13? Posted: 6/8/2012 2:45:56 PM

---

Answer: Per the Typical Sections, where "Type B-12.5 Only" is specified, Type B-12.5 is the only allowable base option. Design Standard Index No. 514 shows a Phi symbol next to 'To be used for widening only, three feet or less', please take note that there is no Phi symbol next to Type B-12.5 thickness for Optional Base Group 13. Status: ANSWER PUBLISHED  
Posted: 6/12/2012 10:12:05 AM