



Bid Questions and Answers Report

Date & Time: 10/12/2012 10:24:17 AM

District Address: District 2 Construction Office, located at 1109 South Marion Avenue, Lake City, FL 32025

District Phone: (386) 961-7532

Proposal: T2440

Project: 427331-1-52-01

Letting Date: 9/26/2012

Location: CENTRAL OFFICE

Description: SR A1A

Question: 1560: Pay Item 515-2-101 is non specified 42" pedestrian picket rail. Posted: 9/19/2012 8:32:19 AM

Can you please specify which index?
Alum or steel?
Which type? Scheme? Case?

The new handrail designs 851, 852, 861, 862 are very specific. These plans are very vague.

Answer: Index 852 applies to both the SR 228 and the SR A1A sidewalk locations.

Status: ANSWER PUBLISHED

Posted: 9/21/2012 12:58:08 PM