



Bid Questions and Answers Report

Date & Time: 10/12/2012 10:25:05 AM

District Address: District 2 Construction Office, located at 1109 South Marion Avenue, Lake City, FL 32025

District Phone: (386) 961-7532

Proposal: T2441

Project: 430896-1-52-01

Letting Date: 9/26/2012

Localtion: CENTRAL OFFICE

Description: SR 16

---

Question: 1524: On this job you show notes for removal of pavement markings, however, there is no pay item for this. Do we need to include this in our costs? Posted: 9/17/2012 4:29:34 PM

---

Answer: The cost for removing any conflicting pavement markings is included in the cost of MOT Lump Sum, per FDOT Specifications 710-4.1 and 102-5.8. Status: ANSWER PUBLISHED  
Posted: 9/19/2012 3:55:12 PM

---

Question: 1556: The pavement marking plans call for preformed thermoplastic pavement markings (arrows and messages) on the asphalt sections of this project. All other markings on the asphalt section are painted, shouldn't the arrows and messages be painted as well? If not will hot applied thermoplastic be acceptable? Posted: 9/18/2012 4:50:59 PM

---

Answer: All arrows and messages for bicycle lane markings shall be preformed thermoplastic, and not paint or hot applied thermoplastic, per Index 17347. All other arrows and messages shall be painted under pay item 710-90. Status: ANSWER PUBLISHED  
Posted: 9/19/2012 3:56:34 PM