



Bid Questions and Answers Report

Date & Time:

5/23/2013 10:09:32 AM

District Address: District 4 Construction Office, located at 3400 West Commercial Blvd. Fort Lauderdale, FL 33309

District Phone: (954) 777-4130

Proposal: T4345

Project: 408362-1-52-01

Letting Date: 5/22/2013

Location: CENTRAL OFFICE

Description: (NE 23 AVE/KINGFISHER WATERWAY BR)

Question:	3952: On sheet 11 for the Optional Materials Tabulation, PVC (ASTM F-949) is listed as an optional material. Per FDOT specifications, HDPE Class II height of cover limitations (min./max.) are identical to PVC (ASTM F-949) requirements. Also environmental conditions and parameter restrictions with regard to both pipe types would be the same. In addition, DCE Memorandum 18-09 allows for direct substitution of HDPE Class II for PVC (ASTM-949). We are requesting clarification and for HDPE Class II to be added and allowed in this section.	Posted: 5/14/2013 4:44:07 PM
-----------	---	------------------------------

Answer:	This project is an off-system (non-FDOT) roadway and bridge replacement project being constructed for the City of Lighthouse Point within the right of way owned by the City. The City is the maintaining agency of the drainage system and roadway. The City had asked FDOT to exclude the use of HDPE drainage pipe based upon their maintenance experience with this type of material in the coastal environment within the City. HDPE drainage pipe has been excluded based upon this reason.	Status: ANSWER PUBLISHED Posted: 5/15/2013 10:49:46 AM
---------	---	---