



Bid Questions and Answers Report

Date & Time:

5/5/2014 1:04:42 PM

District Address: District 1 Construction Office, located at 801 N Broadway, Bartow, FL 33830

District Phone: (863) 519-2222

Proposal: T1566

Project: 200105-7-52-01

Letting Date: 4/30/2014

Location: CENTRAL OFFICE

Description: (OKEECHOBEE TRAILHEAD)

Question:	6858: I could not find a finish for the bike racks, Item 751-36-14. Typical finishes are galvanized steel or powder coated.	Posted:	4/14/2014 6:25:31 PM
Answer:	The finish shall be galvanized steel.	Status:	ANSWER PUBLISHED
		Posted:	4/16/2014 4:49:16 PM
Question:	6909: There is no fixture or fixture trim model numbers to figure the job with. Is it the intent that the plumber design what type of fixture will meet this job needs?	Posted:	4/17/2014 11:27:10 AM
Answer:	Correct. The model numbers are not able to be provided as this is a federally funded project. Per the Comfort Station TSP, Provide items by the same manufacturer and grade/finish as referenced in the TSP.	Status:	ANSWER PUBLISHED
		Posted:	4/21/2014 5:00:56 PM
Question:	6910: Is there a building permit required for the construction of the restroom? If yes what agency will issue the permit and will the cost of the permit be waved?	Posted:	4/17/2014 11:31:36 AM
Answer:	Yes, County building permits will be required. Contact the County for permit fees.	Status:	ANSWER PUBLISHED
		Posted:	4/21/2014 5:05:16 PM