



Bid Questions and Answers Report

Date & Time:

12/5/2014 12:04:28 PM

District Address: District 2 Construction Office, located at 1109 South Marion Avenue, Lake City, FL 32025

District Phone: (386) 961-7532

Proposal: T2566

Project: 434014-1-52-01

Letting Date: 12/3/2014

Location: CENTRAL OFFICE

Description: SR A1A (TIMUCUAN TRAIL)

---

Question: 8526: Can 5" of RAP be used for the Optional Base Group 1? Posted: 11/11/2014 4:03:45 PM

---

Answer: The use of RAP is only allowed for the trail but NOT acceptable for traffic bearing areas. Status: ANSWER PUBLISHED

Posted: 11/17/2014 3:43:43 PM