



Bid Questions and Answers Report

Date & Time:

12/3/2014 8:28:59 AM

District Address: District 4 Construction Office, located at 3400 West Commercial Blvd. Fort Lauderdale, FL 33309

District Phone: (954) 777-4130

Proposal: T4406

Project: 428726-1-52-01

Letting Date: 12/3/2014

Location: CENTRAL OFFICE

Description: SR 5

---

Question:	8540: Sheet T-34, Mast Arm Data Table, specifically provides special drilled shaft dimensions for all of the mast arms. Sheet T-35 provides special foundation details that show different diameters than that shown on Sheet T-34 for mast arms B, C, D, E, F, & J. Please clarify which foundation details are correct.	Posted:	11/13/2014 8:22:34 AM
-----------	---	---------	-----------------------

---

Answer:	Use drilled shaft diameters as shown on Sheet T-34, except for pole "J" which should be 4.5 ft as shown on T-35. Drilled shaft depths as shown on T-35 are correct.	Status:	ANSWER PUBLISHED
		Posted:	11/13/2014 2:14:48 PM