



Bid Questions and Answers Report

Date & Time:

12/3/2014 8:41:23 AM

District Address: District 5 Construction Office, located at 719 South Woodland Blvd, Deland, FL 32720

District Phone: (386) 943-5350

Proposal: T5520

Project: 238678-2-52-01

Letting Date: 12/3/2014

Localtion: CENTRAL OFFICE

Description: SR 500

Question: 8456: Please direct me to or provide information regarding liquidated damages for this project. Posted: 11/6/2014 12:53:47 PM

Answer: Bid Question Answer #8456: Liquidated damages are covered under our Standard Specifications for Road and Bridge Construction, Section 8, Prosecution and Progress. Under Section 8-10.2 Amount of Liquidated Damages, a breakdown is provided to the amount of daily charge per calendar day. This amount is based on the original contract amount. Status: ANSWER PUBLISHED
Posted: 11/25/2014 1:32:03 PM

Question: 8515: Please provide information on or direct us to the number of Days to Completion for this project. Posted: 11/10/2014 3:59:41 PM

Answer: Bid Question Answer #8515: Contract days are 120. Please see the bid solicitation at the following link:
http://www.dot.state.fl.us/cc-admin/Lettings/2014/2014_BSN/dec14/T5520.txt Status: ANSWER PUBLISHED
Posted: 11/25/2014 9:44:51 AM

Question: 8645: There is no "Optional Materials Table" for Drainage Pipe, therefore it does not list HDPE Class II and Polypropylene Pipe as an acceptable material. Both HDPE Class II and Polypropylene Pipe are approved for 100 year DSL applications. We are asking for both HDPE Class II and Polypropylene Pipe to be allowed / included as an optional pipe material (as long as min/max cover requirements are met)so that the contractor community can bid accordingly. Posted: 11/20/2014 3:44:19 PM

Answer: Bid Question Answer #8645: HDPE Class II and Polypropylene Pipe can be used according to the latest edition Drainage Design Manual criteria. The use of an optional pipe is contingent upon satisfying both design service life and structural cover requirements. Status: ANSWER PUBLISHED
Posted: 11/25/2014 1:34:02 PM