



Bid Questions and Answers Report

Date & Time:

3/26/2014 3:01:34 PM

District Address: District 6 Construction Office, located at 1000 NW 111 Ave, Miami, FL 33172

District Phone: (305) 640-7448

Proposal: T6352

Project: 430837-1-52-01

Letting Date: 3/26/2014

Location: CENTRAL OFFICE

Description: SR 5 (OVERSEAS HWY)

---

Question:	6508: The French Drain piping is outside the roadway pavement section to include the paved shoulder. Our interpretation is that the piping for the French Drain underneath a ditch (green area) should be specified according to a 50 year DSL application. According to Note 5 in Table 6-1 of the Drainage Manual, it specifically states French Drain should be considered a 50 year application if replacing this pipe would not require removal and replacement of the project's pavement or curb. All of the French Drain piping is under a ditch away from the roadway section. We are requesting HDPE Class I and Polypropylene Pipe be included as an optional material for a 50 year DSL French Drain application. In addition, we are asking that the connecting conveyance pipe (that connects to the French Drain Piping) within the ditch area be allowed to be HDPE Class I or Polypropylene Pipe. This is based upon the interpretation that the connecting solid pipe is still part of the French Drain system.	Posted: 3/19/2014 2:08:10 PM
-----------	--	------------------------------

---

Answer:	HDPE pipe and Polypropylene (PP) pipe are not allowed in the Keys.	Status: ANSWER PUBLISHED
		Posted: 3/20/2014 12:04:54 PM

---

Answer:	HDPE pipe and Polypropylene (PP) pipe are allowed in the Keys.	Status: ANSWER VOIDED
		Posted: 3/20/2014 11:58:19 AM