



Bid Questions and Answers Report

Date & Time:

5/21/2014 3:55:45 PM

District Address: District 6 Construction Office, located at 1000 NW 111 Ave, Miami, FL 33172

District Phone: (305) 640-7448

Proposal: T6355

Project: 429021-1-52-01

Letting Date: 5/21/2014

Location: CENTRAL OFFICE

Description: SR 5 (US 1)

---

Question: 7123: Note 5 on sheet 19 specifies requirements to fence finishes. May the galvanized metal fence be primed and painted in the field after installation? Posted: 5/7/2014 4:28:18 PM

---

Answer: Primer and paint shall be applied in shop conditions per manufacturer's recommendations. Only paint systems that are designed to work with galvanized steel shall be used. Status: ANSWER PUBLISHED  
Posted: 5/7/2014 4:31:46 PM