



Bid Questions and Answers Report

Date & Time:

6/19/2014 1:57:37 PM

District Address: District 7 Construction Office, located at 11201 N McKinley, Tampa, FL 33612

District Phone: (813) 975-6285

Proposal: T7348

Project: 429074-1-52-01

Letting Date: 6/18/2014

Location: CENTRAL OFFICE

Description: SR 45 (US 41) (50TH ST)

Question: 7259: Drawing sheet B-2, Note M, states that Stay in Place Metal Decking will not be allowed. Posted: 5/21/2014 4:30:17 PM

Can this be revised to allow coated decking material which is normally allowed by the Standard Specification.?

Answer: After considering your request, district structures position is for the Drawing sheet B-2, Note M, to remain as shown on the plans. Status: ANSWER PUBLISHED

Posted: 6/5/2014 2:41:55 PM

Question: 7360: We would like to request a copy of the latest Bridge Inspection Report (BIR, March 2013) as mentioned on sheet B-2 General Notes item O.2. Posted: 6/3/2014 1:41:55 PM

Answer: Please see the three attached files. Status: ANSWER PUBLISHED

Posted: 6/6/2014 9:32:03 AM

Document: 3242215: 100049 BIR - MAR 2013 PART 1.pdf

Bridge Inspection Report.

Document: 3242228: 100049 BIR - MAR 2013 PART 2.pdf

Bridge Inspection Report

Document: 3242234: 100049 BIR - MAR 2013 PART 3.pdf

Bridge Inspection Report

Question: 7452: Please clarify the correct count for pay items #700-5-21 (2 ea) and #700-5-22 (13 ea). Per plans provided the count looks incorrect. Pay item #700-5-21 should be 9 each and #700-5-22 should be 6 each. Posted: 6/11/2014 8:14:58 AM

Answer: The plans include pay item 700-5-22 which has a quantity of 18 as identified in the CES. Pay item 700-5-21 is not included in the plans for 429074-1-52-01 project. Status: ANSWER PUBLISHED
Posted: 6/13/2014 4:33:18 PM