



Bid Questions and Answers Report

Date & Time:

4/29/2015 2:19:41 PM

District Address: District 4 Construction Office, located at 3400 West Commercial Blvd. Fort Lauderdale, FL 33309

District Phone: (954) 777-4130

Proposal: T4416

Project: 431717-1-52-01

Letting Date: 4/29/2015

Location: CENTRAL OFFICE

Description: (NW 15TH WAY), (NW 7TH ST) AND (NW 15TH TERRACE)

---

Question: 9891: Is there a specific detail for the proposed French drain? Posted: 4/20/2015 4:51:55 PM

---

Answer: FDOT standard Index No. 285 is the detail that should be used for the French drain.  
The French drain location and the control structure is detailed in the plans.  
The skimmer used in the control structures is per FDOT standard index No. 241. Status: ANSWER PUBLISHED  
Posted: 4/21/2015 3:12:33 PM

---

Question: 9892: What is to be included in the "landscaping" item and on what plan sheet can the details be evaluated? Posted: 4/20/2015 4:53:11 PM

---

Answer: A separate Landscape Component plan set is included. The Landscape Plan set (sheets LD-1 thru LD-16) details the landscaping needs for this project. Status: ANSWER PUBLISHED  
Posted: 4/22/2015 8:48:37 AM