



Bid Questions and Answers Report

Date & Time:

8/26/2015 8:02:28 AM

District Address: District 2 Construction Office, located at 1109 South Marion Avenue, Lake City, FL 32025

District Phone: (386) 961-7532

Proposal: T2595

Project: 432733-1-52-01

Letting Date: 8/26/2015

Location: CENTRAL OFFICE

Description: SR 93 (I-75)

---

Question: 11281: There is no "Optional Materials Tabulation" for Drainage Pipe for this project therefore neither HDPE Class II nor Polypropylene are included as optional materials. Both HDPE Class II and Polypropylene Pipe are approved for 100 year DSL applications. We are asking for HDPE Class II and Polypropylene Pipe to be allowed/included as an optional pipe material (as long as min/max cover requirements are met). Posted: 8/3/2015 10:10:44 AM

---

Answer: Optional Pipe will not be allowed on this project. Status: ANSWER PUBLISHED

Posted: 8/5/2015 3:04:48 PM