



Bid Questions and Answers Report

Date & Time:

2/25/2015 9:12:57 AM

District Address: District 4 Construction Office, located at 3400 West Commercial Blvd. Fort Lauderdale, FL 33309

District Phone: (954) 777-4130

Proposal: T4410

Project: 433070-1-52-01

Letting Date: 2/25/2015

Location: CENTRAL OFFICE

Description: (23RD ST) AND (SPRUCE AVE)

---

Question: 9023: The "Optional Materials Tabulation" for Drainage Pipe does not include HDPE Class II or Polypropylene Pipe as an acceptable material. Both HDPE Class II and Polypropylene Pipe are approved for 100 year DSL applications. We are asking for HDPE Class II and Polypropylene Pipe to be allowed/included as an optional pipe material (as long as min/max cover requirements are met). Posted: 2/5/2015 10:35:41 AM

---

Answer: HDPE Class II and Polypropylene Pipe may be allowed/included as an optional pipe material (as long as min/max cover requirements are met). Status: ANSWER PUBLISHED  
Posted: 2/12/2015 12:19:37 PM