



Bid Questions and Answers Report

Date & Time: 2/25/2015 9:24:09 AM

District Address: District 6 Construction Office, located at 1000 NW 111 Ave, Miami, FL 33172

District Phone: (305) 640-7448

Proposal: T6376

Project: 430817-1-52-01

Letting Date: 2/25/2015

Location: CENTRAL OFFICE

Description: SR 7 (NW 7TH AVE)

---

Question: 9056: The "Optional Materials Tabulation" for Drainage Pipe does not include Polypropylene Pipe as an acceptable material. Polypropylene Pipe is approved for 100 year DSL applications. We are asking for Polypropylene Pipe to be allowed/included as an optional pipe material (as long as min/max cover requirements are met). Posted: 2/11/2015 3:05:32 PM

---

Answer: Polypropylene Pipe is an acceptable material on this project. Status: ANSWER PUBLISHED

Posted: 2/12/2015 5:31:05 PM