



Bid Questions and Answers Report

Date & Time:

7/29/2015 8:23:53 AM

District Address: District 3 Construction Office, located at 1074 Highway 90 East, Chipley, FL 32428

District Phone: (850) 415-9713

Proposal: T3514

Project: 430781-1-52-01

Letting Date: 7/29/2015

Localtion: CENTRAL OFFICE

Description: SR 30 (US 98)

---

Question: 11196: Sheet 69 of the plans shows the used of 4 locations of rumble strips on each end of a lane closure. Index # 603, sheet 1 of 2, also included in the plans, indicates the use of 1 location of rumble strips on each end of a lane closure. Please clarify which setup is to be used. Posted: 7/23/2015 9:09:51 AM

---

Answer: Rumble strips shall be in accordance with Std. Index 603 Sheet 1 of 2. Status: ANSWER PUBLISHED  
Posted: 7/23/2015 12:06:13 PM

---

Question: 11224: On Sheet 5, Typical Section #1, there is a note that states, "Details for Cross Slopes Outside the Allowable Tolerance of 0.015 Ft/Ft to 0.003 Ft/Ft are Tabulated in the Summary of Quantities. See Sheet 8." Is the range specified correct? Or should it be 0.03 Ft/Ft? Posted: 7/24/2015 5:46:00 PM

---

Answer: Questions posted to this site before 5:00 P.M. (EST) on the seventh calendar day prior to the bid opening, or tenth day prior to the December bid opening will be responded to by the Department. For Questions posted after these times, an answer cannot be assured. Status: ANSWER PUBLISHED  
Posted: 7/27/2015 3:26:11 AM