



Bid Questions and Answers Report

Date & Time:

7/29/2015 8:37:00 AM

District Address: District 4 Construction Office, located at 3400 West Commercial Blvd. Fort Lauderdale, FL 33309

District Phone: (954) 777-4130

Proposal: T4376

Project: 427012-1-52-01

Letting Date: 7/29/2015

Localtion: CENTRAL OFFICE

Description: SR 823 (FLAMINGO RD)

---

Question: 11093: Per the plan sheet S-6 the street name signs for Flamingo Rd are to be 66" wide. Per FDOT index 11860 no single post mounted sign shall have a width exceed 60". Please advise. Posted: 7/10/2015 10:34:28 AM

---

Answer: Based on a structural check the 66" wide sign can be used using DSI 11860. See calculations attached. Status: ANSWER PUBLISHED

Posted: 7/13/2015 4:42:25 PM

---

Document: 4165365: Z Check for Single Post.pdf

Supporting Structural Calculations

---

Question: 11094: Isn't it slightly overkill to have the street name signs so large? The total SF of a typical Stop Sign assembly with street name signs is over 40 SF. The wrong pay item is being used. Posted: 7/10/2015 10:36:38 AM

---

Answer: It is acknowledged that the street name signs seem excessive but its design is as per design standard criteria for a multi-lane facility with speed limit greater than 40 mph. Pay item 700-1-14 (single post sign, ground mount with combined sheeting area of all panels on post greater than 31 sf) shown in the plans is correct. Status: ANSWER PUBLISHED

Posted: 7/13/2015 4:42:54 PM