



Bid Questions and Answers Report

Date & Time: 7/29/2015 8:37:47 AM

District Address: District 4 Construction Office, located at 3400 West Commercial Blvd. Fort Lauderdale, FL 33309

District Phone: (954) 777-4130

Proposal: T4396

Project: 428732-1-52-01

Letting Date: 7/29/2015

Localtion: CENTRAL OFFICE

Description: SR-816 (OAKLAND PARK BLVD)

| | | | |
|-----------|---|---------|----------------------|
| Question: | 11109: The "Optional Materials Tabulation" for Drainage Pipe does not include HDPE Class II or Polypropylene Pipe as an acceptable material. Both HDPE Class II and Polypropylene Pipe are approved for 100 year DSL applications. We are asking for HDPE Class II and Polypropylene Pipe to be allowed/included as an optional pipe material for all pipe sizes (as long as min/max cover requirements are met). | Posted: | 7/13/2015 4:11:49 PM |
|-----------|---|---------|----------------------|

| | | | |
|---------|--|---------|-----------------------|
| Answer: | HDPE Class II and Polypropylene Pipe are allowed to be included as an optional pipe material for all pipe sizes as long as min/max cover requirements are met. | Status: | ANSWER PUBLISHED |
| | | Posted: | 7/17/2015 10:39:09 AM |