



Bid Questions and Answers Report

Date & Time:

6/17/2015 8:25:11 AM

District Address: District 4 Construction Office, located at 3400 West Commercial Blvd. Fort Lauderdale, FL 33309

District Phone: (954) 777-4130

Proposal: T4420

Project: 430595-1-52-01

Letting Date: 6/17/2015

Location: CENTRAL OFFICE

Description: SR A1A

---

Question: 10567: The Typical Section for Shoulder Construction (sheet nos. 5 and 6) calls for Optional Base Group 9 (6.00"). Per the Design Standards for Base Thickness and Option Codes this would indicate the use of Type B-12.5 for the base material. Is that the specific intended material or are the other options in that Base Group acceptable? Posted: 6/1/2015 9:54:27 AM

---

Answer: The (6.00") requirement shown in the plans was meant to specify the use of B-12.5. Status: ANSWER PUBLISHED

Posted: 6/3/2015 2:44:02 PM