



Bid Questions and Answers Report

Date & Time:

6/17/2015 8:27:23 AM

District Address: District 5 Construction Office, located at 719 South Woodland Blvd, Deland, FL 32720

District Phone: (386) 943-5350

Proposal: T5531

Project: 428213-2-52-02

Letting Date: 6/17/2015

Localtion: CENTRAL OFFICE

Description: SR 93 (I-75)

Question:	10647: I was wondering about a new bid item that is listed on this project.0000-500-1 Signalization Design Group Generic Pay Item SCADA System Assembly F & I (AS) SCADA Assembly F & I (AS). My question is the plans call for a engineer to design and submit a set of plans before we call install this system. On other projects you had another company that was to test all systems after they where done (Veterans Projects.) how will this SCADA System work on the testing of Equipment after it is installed. Will another company come in a test all systems or just the SCADA system? And if there will be another company who will they be? Also the unit of measurement is ZZ and it show's 24 total Assemblies.	Posted: 6/9/2015 9:12:19 AM
-----------	--	-----------------------------

Answer:	Bid Question Response #10647: The Department will test the SCADA system. The assemblies and required components are specified within the provided TSP. The ZZ in the Summary of Pay Items should read AS as indicated in the Tabulation of Quantities. The 0000-500-1 pay item shall be bid with a quantity of 24 AS.	Status: ANSWER PUBLISHED Posted: 6/15/2015 7:21:20 AM
---------	---	--