



Bid Questions and Answers Report

Date & Time: 3/25/2015 10:35:45 AM

District Address: District 6 Construction Office, located at 1000 NW 111 Ave, Miami, FL 33172

District Phone: (305) 640-7448

Proposal: T6374

Project: 431180-1-52-01

Letting Date: 3/25/2015

Location: CENTRAL OFFICE

Description: SR 934 (NE 79TH ST) (JF KENNEDY CSWY)

---

Question: 9295: Item 0515-2311 is described as Pedestrian/Bicycle Railing, Aluminum Only, 42" Type 1. The Summary of Railing table on Sh SQ-28 has the same description. That description is for Index 862.

Posted: 3/4/2015 2:31:17 PM

However, on plan sheets 13, 31 and 32 the railing is described as Pipe Guiderail Index 870.

Please clarify which Index is to be used.

Thanks.

---

Answer: Aluminum Pipe Guiderail shall be constructed per Index 870 of the Design Standards. Guiderail shall be paid for under the contract unit price for Pedestrian/Bicycle Railing, LF (Pay Item No. 0515-2311).

Status: ANSWER PUBLISHED

Posted: 3/5/2015 1:54:45 PM