



Bid Questions and Answers Report

Date & Time: 5/21/2015 3:53:41 PM

District Address: District 1 Construction Office, located at 801 N Broadway, Bartow, FL 33830

District Phone: (863) 519-2222

Proposal: T1609

Project: 433373-1-52-01

Letting Date: 5/20/2015

Location: CENTRAL OFFICE

Description: SR 72

---

Question: 10260: Following a site visit the existing white edge marking is an audible type and not simply thermoplastic. The proposed plans show this white edge line as thermoplastic. Is the intent to provide the edge line to match existing? Posted: 5/8/2015 3:45:12 PM

---

Answer: The intent of the proposed plans are correct. The 6" white edge line is standard thermoplastic and not audible vibratory type. Status: ANSWER PUBLISHED

Posted: 5/12/2015 2:31:25 PM