



Bid Questions and Answers Report

Date & Time:

5/21/2015 4:00:09 PM

District Address: District 3 Construction Office, located at 1074 Highway 90 East, Chipley, FL 32428

District Phone: (850) 415-9713

Proposal: T3488

Project: 409792-7-52-01

Letting Date: 5/20/2015

Localtion: CENTRAL OFFICE

Description: SR 292 (GULF BEACH HWY) AND SR 295 (NAVY BLVD)

Question: 10324: The "Optional Materials Tabulation" for Drainage Pipe does not include HDPE Class II or Polypropylene Pipe as an acceptable material for Structures S-22, S-31, S-35, S-37, S-38, S-39, S-40, S-42, S-43, S-44, S-49, and S-53 . We are asking for HDPE Class II and Polypropylene Pipe to be allowed/included as an optional pipe material for these stated structures (as long as min/max cover requirements are met). Posted: 5/12/2015 11:13:18 AM

Answer: HDPE (High Density Polyethylene) Class II and PP (Polypropylene) Class II pipe is allowed as an optional pipe material for all pipe on the project, as long as minimum and maximum cover requirements are met. Status: ANSWER PUBLISHED
Posted: 5/14/2015 8:26:37 AM