



Bid Questions and Answers Report

Date & Time:

8/31/2016 8:29:36 AM

District Address: District 3 Construction Office, located at 1074 Highway 90 East, Chipley, FL 32428

District Phone: (850) 415-9713

Proposal: T3576

Project: 428576-1-52-01

Letting Date: 8/31/2016

Localtion: CENTRAL OFFICE

Description: REDDICK MILL RD

---

Question: 15421: According to Specification 530-3.3 a minimum of one foot of bedding stone is to be placed under all rubble riprap. Is bedding stone required for this project? And does the Department intend to add a bid item for Bedding Stone or does the tonnage of rubble riprap include the quantity of bedding stone needed for the project? Posted: 8/23/2016 2:17:51 PM

---

Answer: Bedding Stone will not be required for this contract. Status: ANSWER PUBLISHED

Posted: 8/25/2016 2:23:02 PM