



Bid Questions and Answers Report

Date & Time:

1/27/2016 8:23:12 AM

District Address: District 6 Construction Office, located at 1000 NW 111 Ave, Miami, FL 33172

District Phone: (305) 640-7448

Proposal: T6385

Project: 433264-1-52-01

Letting Date: 1/27/2016

Location: CENTRAL OFFICE

Description: SR 94/SW 88 ST/KENDALL DR

---

Question: 12889: Bid Items 0520-5-41 & 42 Traffic Separator Concrete Type IV 4'wide and 6' Wide; the typical sections indicate to use Option II. When referring to the design standards Index No. 302 it mentions that the asphalt pavt' structural course and base material to be included in the cost of the separator. Are the quantities for the asphalt and base part of the bid items > 0334-1-13 Superpave Traffic C and 0285-710 OBG-10 or incidental? Please clarify?

Posted: 1/13/2016 12:15:12 PM

---

Answer: The asphalt and base quantities for the proposed concrete traffic separators were included in Pay Items 0334-1-13 - Superpave Asphalt Traffic C and 0285-710 - Optional Base Group 10.

Status: ANSWER PUBLISHED

Posted: 1/14/2016 1:56:42 PM