



Bid Questions and Answers Report

Date & Time:

6/15/2016 9:09:02 AM

District Address: District 2 Construction Office, located at 1109 South Marion Avenue, Lake City, FL 32025

District Phone: (386) 961-7532

Proposal: T2618

Project: 430910-1-52-01

Letting Date: 6/15/2016

Location: CENTRAL OFFICE

Description: SR 152 (BAYMEADOWS RD)

---

Question: 14839: There is not a Typical Section that indicates what the pavement sections are from Sta. 405+20 to 406+89. What pavement section is the Contractor meant to construct within these stations? Posted: 6/2/2016 4:48:34 PM

---

Answer: The station range in question is on Old Baymeadows Road at the intersection of Southside Blvd. The pavement design intended for this area is the same design used on the other section of Old Baymeadows Road. See Typical Section No. 8 on sheet 18. This is also the values used in the quantities table on the SQ sheets. The cautionary notes for that typical will apply as well. Status: ANSWER PUBLISHED  
Posted: 6/3/2016 8:25:42 AM

---

Question: 14849: The "Optional Materials Tabulation" for Drainage Pipe does not include Polypropylene Pipe as an acceptable material. Polypropylene has been approved for 100 year DSL applications. We are asking for Polypropylene Pipe to be allowed/included as an optional pipe material (as long as min/max cover requirements are met). Posted: 6/3/2016 9:11:05 AM

---

Answer: The only optional material allowed are those shown in the "Optional Materials Tabulation" in the plans. Status: ANSWER PUBLISHED  
Posted: 6/3/2016 11:09:07 AM