



Bid Questions and Answers Report

Date & Time: 10/26/2016 12:39:25 PM

District Address: District 3 Construction Office, located at 1074 Highway 90 East, Chipley, FL 32428

District Phone: (850) 415-9713

Proposal: T3599

Project: 428208-3-52-01

Letting Date: 10/26/2016

Localtion: CENTRAL OFFICE

Description: SR 30 (US 98)

Question: 15997: On sheet #4, in the typical section, there is 15" of GAB. On sheet SQ-3, summary of pavement, there is OBG1 and OBG11. Could you please clarify the departments intent? Posted: 10/17/2016 5:50:29 PM

Answer: We intend for you to bid the 15" of GAB. The two pay items were used to account for payment of the base since the 15" designed depth of the graded aggregate base exceeded the maximum allowed by FDOT Design Standards. Status: ANSWER PUBLISHED
Posted: 10/21/2016 2:21:16 PM