



Bid Questions and Answers Report

Date & Time:

10/26/2016 8:49:02 AM

District Address: District 4 Construction Office, located at 3400 West Commercial Blvd. Fort Lauderdale, FL 33309

District Phone: (954) 777-4130

Proposal: T4446

Project: 432949-1-52-01

Letting Date: 10/26/2016

Location: CENTRAL OFFICE

Description: OLD DIXIE HWY

---

Question: 15969: Will a separate pay item(s) be included for the Type F curb & gutter as well as the drop curb that appears on the Roadway plans? Posted: 10/17/2016 8:50:19 AM

---

Answer: Yes, pay item 520-1-10 for type F curb and gutter and its associated drop curb, with a quantity of 1516 LF will be added to the plans. A revision to reflect this will be forth coming prior to letting. Status: ANSWER PUBLISHED

Posted: 10/19/2016 9:03:05 AM

---

Question: 16021: Of what material are the primary and secondary neighborhood monument signs? Are they masonry signs? Is aluminum acceptable? Posted: 10/19/2016 11:03:08 AM

---

Answer: The Plans provide dimensions, surface textures/finishes only. The Contractor (via Specialty Engineer) is to provide the structural design and signed and sealed shop drawings that meet local code. For the internal frame of the structure. The plans only show the overall dimensions and exterior finishes, which are all masonry items, however, the materials underneath are up to the contractor's preference. Status: ANSWER PUBLISHED

Posted: 10/22/2016 8:42:22 AM