

NOTICE TO CONTRACTORS
OFFICE OF THE STATE OF FLORIDA
DEPARTMENT OF TRANSPORTATION
801 N. BROADWAY AVENUE
BARTOW, FLORIDA 33830

December 1, 2010

District Procurement Office, District One

ADDENDUM NUMBER ONE

PROJECT DESCRIPTION: Roof and HVAC Replacement, D1 Materials Lab
FINANCIAL PROJECT NOS.: 425639-1-52-01 & 427895-1-52-01
COUNTIES: Polk
CONTRACT NO.: E1J21

Request For Proposal	Page	
	10	F. Contract Duration was and revised as follows: <i>The Design/Build Firm shall establish the contract duration for the subject project. In no event shall the contract duration exceed 120 calendar days. The schedule supporting the proposed contract duration will be submitted with the Technical Proposal and the Bid Price Proposal.</i>

*Attached to this Addendum is a revised copy of the Request for Proposal package (December 1, 2010).

Question: Asked during the pre-proposal meeting, 11-23-10. Can we slice the roof to measure the thickness?

Answer: No. The Department will provide this information. Samples were taken by the Department as follows: At the middle of the roof where the roof pitches downward the core sample was 5" thick and at both lower ends of the roof it was 3 ½ " thick. Roofing material consisted of two plies and fibered insulation to the decking material.

Acknowledge receipt of Addendum Number One in the space provided on the proposal.

Cheryl Sanchious

Cheryl L. Sanchious

District Contracts Administrator

PLEASE SIGN BELOW IN RECEIPT OF THIS NOTICE AND ADDITIONAL DOCUMENTS ANNOTATED ABOVE.

Signature

Date

Company Name