



## Florida Department of Transportation

CHARLIE CRIST  
GOVERNOR

1109 S. Marion Avenue  
Lake City, Florida 32025

STEPHANIE C. KOPELOUSOS  
SECRETARY

March 20, 2009

To: Prospective Bidders and Plan Holders

**Addendum No: 1, E2M94, Financial Project #42398915201  
Jacksonville Urban Office Rooftop Chiller Replacement**

The Department has received requests from three different manufactures (Carrier, Trane and McQuay) to consider various chillers as alternates for the Jacksonville Urban Office rooftop chiller replacement project (E2M94). Based on the submittals, and in an effort to promote competitive bidding, it has been decided that it is in the best interest of the Department to reduce the minimum chiller efficiency rating for this project to 15.0 EER (IPLV). Based on this new criteria the following submitted alternates are **APPROVED**:

<b><u>Manufacturer</u></b>	<b><u>Model Number</u></b>
Trane	CGAM110D2
Carrier	30XA110

The following submitted alternates are **DENIED** based on their lower efficiency ratings:

<b><u>Manufacturer</u></b>	<b><u>Model Number</u></b>
Carrier	30RB100
McQuay	AGZ100C

You must sign, date and fax a copy of this addendum back to me by close of business today to indicate receipt. A copy of this addendum must be returned with your bid.

---

Company Name

---

Signature

---

Date

Thanks,

Patsy Elkins  
Contracts Coordinator  
Phone: 386-758-3703  
Fax: 386-758-3791