



Florida Department of Transportation

CHARLIE CRIST
GOVERNOR

1109 South Marion Avenue
Lake City, Florida 32025

STEPHANIE C. KOPELOUSOS
SECRETARY

October 5, 2009

To: Prospective Bidders and Plan Holders

Addendum No.: **1, E2N98, Financial Project # 213896145201**
Chiefland Maintenance automated Security Gates

Questions and answers:

1. Can we use equipment to dig trenches
ANSWER: Yes, after contacting Florida One Call.
2. Does it have to be hand dug
ANSWER: Only around marked or know utilities.
3. Do they want all to be directional bored
ANSWER: No, conduit can be pushed under drives. Pavement shall not be cut except for installation of traffic loops.
4. May wire be run through attic
ANSWER: Yes

You must sign, date and fax a copy of this addendum back to me by close of business today to indicate receipt. A copy of this addendum must be returned with your bid.

Company Name

Date

Signature

Thanks,

Patsy Elkins, CPPB
Contracts Coordinator
Phone: 386-758-3703
Fax: 386-758-3791