



Florida Department of Transportation

RICK SCOTT
GOVERNOR

1109 S. Marion Avenue
Lake City, Florida 32025

ANANTH PRASSAD P.E.
SECRETARY

May 20, 2011

To: Proposal Holders

**Addendum No: 1, E2P96, Financial Project #42557125201
HVAC Modifications – Jacksonville Maintenance Administration Building in
Duval County**

The following information that was discussed at our 5/12/11 mandatory pre-bid meeting:

1. Counties identified on the bid documents should read St. Johns and Putnam.
2. Base bid shall include painted cabinet fuel dispensers for both sites. Color shall be white.
3. All dispensers shall include new high hose retrievers. Delete retractors from original scope of services. Existing high hose retrievers at Palatka are mounted extra high; new retractors can be installed at standard height above fuel dispensers.
4. Owner shall provide new dispenser decals.
5. New unions and shear valves shall be furnished and installed with all new fuel dispensers.
6. All coordination for Fuel Master shall be directed through Angel Birriel, FDOT Mobile Equipment Manager, 850-410-5517.
7. St. Augustine and Palatka spill buckets shall remain in place. Contractor shall include hydrostatic test on all sumps as part of overall final testing and certification requirements.
8. Include the following added cost alternates on bid proposal:
 - Alternate #1 – Furnish and install stainless steel cabinets for St. Augustine fuel dispensers.
 - Alternate #2 – Furnish and install stainless steel cabinets for Palatka fuel dispensers.
 - Alternate #3 – Provide extended fuel dispenser warranty to cover a total of three (3) years. **Copy of sample warranty shall be included with bid documents.**

The Revised bidding documents are attached to this addendum. You must utilize these documents or your bid will be found non responsive.

You must sign, date and fax a copy of this addendum back to me by close of business today to indicate receipt. A copy of this addendum must be returned with your bid.

Company Name

Signature

Date

Thanks,
Patsy Elkins, CPPB
Contracts Coordinator
Phone: 386-758-3703
Fax: 386-758-3791