



Florida Department of Transportation

RICK SCOTT
GOVERNOR

1109 S. Marion Avenue
Lake City, Florida 32025

ANANTH PRASAD
SECRETARY

July 12, 2011

To: Proposal Holders

Addendum No: 1, E2Q13, Financial Project # 42557125201
Remove and replace Attic Insulation – Jacksonville Maintenance Administration Building in Duval County.

Questions and Answers:

1. The 16 calendar days to complete this project seems a little short. Can we extend that construction schedule to 30 calendar days upon the receipt of notice to proceed?

ANSWER: Yes, contract time will be extended to provide 25 calendar days for substantial completion and 5 calendar days for final completion, for a total of 30 calendar days.

2. Does the installation of the insulation need to meet Florida Building Code requirements? Please see attached.

ANSWER: Yes, building code requirements must be met but it is our interpretation that Section 1203.2 is not applicable for this application because we are not installing a ceiling "directly to the underside of roof framing members". After the attic space is sealed from exterior ambient air it basically becomes part of the conditioned space of the building. Outside makeup air is introduced through the HVAC system.

Attached are the Revised Bid Documents for the above referenced project to reflect the change in Calendar Days. Also page 15 of the Non-Technical Specifications is attached and has been revised to reflect the change in Substantial Completion days to 25 and Final Completion days to 5.

You must sign, date and fax a copy of this addendum back to me by close of business today to indicate receipt. A copy of this addendum must be returned with your bid.

Company Name

Signature

Date

Thanks,
Patsy Elkins, CPPB
Contracts Coordinator
Phone: 386-758-3703
Fax: 386-758-3791