



Florida Department of Transportation

**RICK SCOTT
GOVERNOR**

1109 S. Marion Avenue
Lake City, Florida 32025-5874

**ANANTH PRASAD, P.E.
SECRETARY**

September 23, 2014

To: Prospective Bidders

**Addendum No.: 2, E2T43, Financial Project # 42557145215
Fuel Dispensers for Jacksonville Maintenance Facility**

QUESTION AND ANSWER:

QUESTION: It states that the gasoline hoses to be 3/4". Are the diesel hoses and nozzles to be 3/4" as well or are they 1"? Did I understand that "Exhibit 5 Insurance Certificate" has to be completed and submitted with my bid proposal or is this only to the contractor at the time of the award?

ANSWER: The diesel hoses and nozzles shall be the larger 1" and Unleaded fuel shall be 3/4". Yes you are required to provide exhibit 5 Insurance Certificate with the bid.

You must sign, date and fax a copy of this addendum back to me by close of business today to indicate receipt. The bidder is required to acknowledge the addendum in the space provided on the proposal.

Company Name

Date

Signature

Jim Brown
District Contracts Administrator
Phone: 386-758-3798
Fax: 386-758-3791