



Florida Department of Transportation

RICK SCOTT
GOVERNOR

1074 Hwy 90
Chipley, Florida 32428

JIM BOXOLD
SECRETARY

November 3, 2015

ADDENDUM NO. 2

To: ALL PLANS AND/OR PROPOSAL HOLDERS

FINANCIAL ITEM NUMBER: 42548445201

CONTRACT NUMBER: E3P13 (FCO)

DESCRIPTION: The work performed under this contract includes replacement of chiller unit in Administration Building in Washington County.

BIDS TO BE RECEIVED: November 12, 2015

If you are a PLANS and/or PROPOSAL HOLDER, this is your authorization to make the following changes to the plans package you now have for the subject project:

Please use the following answers to the questions below when bidding on the above referenced project:

1. Can the generator feed for the new chiller (600 amp) come from the existing 800 amp emergency panel located in the administration building? All is required is to install a 600 amp breaker in this panel. This panel is already controlled from an ATS located in the generator room. **Yes, but the contractor must verify that the existing wire size is sufficient for the larger 600 amp breaker.**
2. Please review the license requirements for contracting. The licensed trades on site will be concrete, electrical, controls, mechanical. This falls under contracting, either a G.C. or CBC license is required. Please advise. **Please see the clarification in this addendum concerning concrete work. The minimum contractor license requirement for this contract will be HVAC and electrical license or general contractor license, or certified building contractor license.**

Please use the following clarifications when bidding on the above referenced project:

1. Florida Department of Transportation will provide the necessary material and labor for the concrete slab required for the installation of the new 120 Ton Chiller unit. The Contractor will coordinate with the Department for any required slab penetrations and conduits as required before slab is poured.

Sealed bids will be received until 2:00 p.m. local time on November 12, 2015 in the District Three Procurement Services Conference Room, Room 230, Administration Building, 1074 Highway 90, Chipley, Florida.

Please use this revision when preparing your bid.

AMENDMENT NOTIFICATION

If you are a PROPOSAL HOLDER, please acknowledge receipt of the addendum under the Acknowledgement of Addenda section of your bid proposal.

Sincerely,

Richard Norris
District Contracts Administrator
RN:am

c.c. Chris Kneiss, Heath Riley, file