



## Florida Department of Transportation

CHARLIE CRIST  
GOVERNOR

3400 West Commercial Boulevard  
Fort Lauderdale, FL 33309-3421

STEPHANIE C. KOPELOUSOS  
SECRETARY

December 8, 2010  
By e-mail

Dear Bidders:

RE: ADDENDUM ONE – Broward County Contract E4L98, Install Fire Hydrants I-595  
FM 42080995201

1. As noted at the mandatory pre-bid meeting, the deadline to submit bidder requirements moved from Friday, December 2, 2010 by 5 pm to Tuesday, December 6, 2010 by 5 pm.
2. Informational Plan Sheet Revisions as follows:

Plan Sheet

- A-1 Added "Revisions" section to Key Sheet
- A-2 Revised language for pay item notes for 1050-11-423 and 1644-133-08
- A-3 Increased text size. Revised General Note 14 and 15 to require 18 inch clearance. Revised Water System Note 4 to required 18 inch clearance. Revised Water System Note 13 leakage formula denominator from 133,000 to 148,000. Revised Water System Note 14 from 90 to 60 days. Added Water System Note 18.
- A-4 Removed the detail for fire hydrant installation within sidewalk. Revised clearance to be 18 inches.

Please replace the plan sheets with the attached revised plan sheets.

Sincerely,

Esther Brandt for

Lizz Holmes, CPPB  
Procurement Supervisor  
District 4, District Contracts

LH:eb  
Copy: File, Kelley Hall