Florida Department of Transportation

RICK SCOTT
GOVERNOR

719 S. Woodland Blvd.
DeLand, FL 32720

ANANTH PRASAD, P.E.
SECRETARY

October 17, 2014

ADDENDUM NO. 1

To: PROSPECTIVE BIDDERS

FINANCIAL PROJECT NUMBER: 418076-8-52-01
CONTRACT NUMBER: E5L19
COUNTY: Orange
DESCRIPTION: Remove/Replace Emergency Generator/Main Breaker Panel

---

CHANGES IN SPECIFICATIONS AND PLANS

The advertised Specification Package and Plans have been changed to reflect some of the issues that were brought up at the Pre-Bid Meeting on October 15, 2014. See attached "Addendum No. One", it is the contractors responsibility to verify the changes made to both the Specifications and Plans that were given and prepare your bids accordingly.

Please sign the Addendum in the space provided and email, mail or fax back verifying receipt. If you have any further questions please contact Jamie Carter at (386) 943-5525 or by email at jamie.carter@dot.state.fl.us. Fax to: (850) 412-8092.

Sincerely,

Roger Masten
District Contracts Administrator
District Five

Received by: _____

Company: _____

Date: _____

FLORIDA DEPARTMENT OF TRANSPORTATION
DISTRICT FIVE
EMERGENCY POWER IMPROVEMENTS
ORLANDO URBAN OFFICE

ADDENDUM NO. One

1.1 General

A. Existing generator and all other items to be removed shall become the ownership of the contractor and removed from site upon completion of work.

1.2 Refer to Drawings

A. Sheet AG-001

1. Notes A4: Delete note "1" and reference to work pertaining to existing fuel tank. Department will empty tank and will retain a remediation contractor to execute this work.

2. Partial Enlarged Site Plan: Remove generator exhaust pipe and supports and repair wall filling all penetrations with grout. Paint repaired areas to blend with wall paint color.

1.3 A. Fuel for new generator shall be furnished by the Department. Delete all references of Contractor furnishing diesel fuel for new generator.